

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	NYSDOH Action Level	Units
E-1 CLASSROOM 1	5/24/2024 07:38	6/7/2024 11:36	70299763001	Lead	2.3	5	ug/L
E-2 CLASSROOM 2	5/24/2024 07:39	6/7/2024 11:42	70299763002	Lead	1.1	5	ug/L
E-3 CLASSROOM 3	5/24/2024 07:40	6/7/2024 11:46	70299763003	Lead	1.8	5	ug/L
E-4 CLASSROOM 4	5/24/2024 07:41	6/7/2024 11:51	70299763004	Lead	3.0	5	ug/L
E-5 CLASSROOM 5	5/24/2024 07:42	6/7/2024 11:52	70299763005	Lead	1.6	5	ug/L
E-6 CLASSROOM 6	5/24/2024 07:43	6/7/2024 11:54	70299763006	Lead	1.8	5	ug/L
E-7 CLASSROOM 7	5/24/2024 07:45	6/7/2024 11:55	70299763007	Lead	1.7	5	ug/L
E-8 CLASSROOM 8	5/24/2024 07:46	6/7/2024 11:57	70299763008	Lead	<1.0	5	ug/L
E-9 CLASSROOM 9	5/24/2024 07:47	6/7/2024 11:59	70299763009	Lead	1.7	5	ug/L
E-11 CLASSROOM 10	5/24/2024 07:49	6/7/2024 12:00	70299763010	Lead	1.6	5	ug/L
E-12 NURSE	5/24/2024 07:53	6/7/2024 12:02	70299763011	Lead	2.5	5	ug/L
E-13 RM11/12	5/24/2024 07:55	6/7/2024 12:03	70299763012	Lead	<1.0	5	ug/L
E-14 RM13	5/24/2024 07:53	6/7/2024 12:05	70299763013	Lead	1.5	5	ug/L
E-15 RM14	5/24/2024 07:55	6/7/2024 12:09	70299763014	Lead	3.3	5	ug/L
E-16 RM15	5/24/2024 07:56	6/7/2024 12:11	70299763015	Lead	1.7	5	ug/L
E-17 RM49	5/24/2024 07:57	6/7/2024 12:12	70299763016	Lead	3.6	5	ug/L
E-18 RM16	5/24/2024 07:58	6/7/2024 12:14	70299763017	Lead	2.7	5	ug/L
E-19 RM17	5/24/2024 07:59	6/7/2024 12:15	70299763018	Lead	1.9	5	ug/L
E-20 RM18	5/24/2024 08:00	6/7/2024 12:17	70299763019	Lead	1.4	5	ug/L
E-21 RM19	5/24/2024 08:01	6/7/2024 12:19	70299763020	Lead	3.7	5	ug/L
E-22 RM20	5/24/2024 08:05	6/7/2024 12:23	70299763021	Lead	1.5	5	ug/L
E-23 RM21	5/24/2024 08:07	6/7/2024 12:31	70299763022	Lead	2.0	5	ug/L
E-24 RM47	5/24/2024 08:08	6/7/2024 12:35	70299763023	Lead	1.4	5	ug/L
E-25 RM46	5/24/2024 08:09	6/7/2024 12:37	70299763024	Lead	1.7	5	ug/L
E-26 RM22	5/24/2024 08:10	6/7/2024 12:38	70299763025	Lead	1.0	5	ug/L
E-27 RM23	5/24/2024 08:11	6/7/2024 12:40	70299763026	Lead	1.2	5	ug/L
E-28 RM45	5/24/2024 08:11	6/7/2024 12:41	70299763027	Lead	2.2	5	ug/L
E-29 RM44	5/24/2024 08:13	6/7/2024 12:46	70299763028	Lead	2.3	5	ug/L
E-30 RM43	5/24/2024 08:15	6/7/2024 12:47	70299763029	Lead	2.1	5	ug/L
E-31 RM42	5/24/2024 08:16	6/7/2024 12:49	70299763030	Lead	2.4	5	ug/L
E-32 RM25	5/24/2024 08:16	6/7/2024 12:51	70299763031	Lead	<1.0	5	ug/L
E-33 RM26	5/24/2024 08:18	6/7/2024 12:52	70299763032	Lead	1.3	5	ug/L
E-34 RM27	5/24/2024 08:18	6/7/2024 12:54	70299763033	Lead	1.1	5	ug/L
E-35 RM41	5/24/2024 08:19	6/7/2024 12:55	70299763034	Lead	2.1	5	ug/L
E-36 RM40	5/24/2024 08:21	6/7/2024 12:57	70299763035	Lead	2.2	5	ug/L
E-37 RM28	5/24/2024 08:22	6/7/2024 12:58	70299763036	Lead	2.9	5	ug/L
E-38 RM29	5/24/2024 08:23	6/7/2024 13:00	70299763037	Lead	2.9	5	ug/L
E-39 RM30	5/24/2024 08:23	6/7/2024 13:04	70299763038	Lead	2.3	5	ug/L
E-40 RM31	5/24/2024 08:24	6/7/2024 13:06	70299763039	Lead	2.1	5	ug/L
E-41 RM32	5/24/2024 08:27	6/7/2024 13:07	70299763040	Lead	8.3	5	ug/L
E-42 BACKHALL RT-BF	5/24/2024 08:27	6/7/2024 13:12	70299763041	Lead	<1.0	5	ug/L
E-43 BACKHALL RT-F	5/24/2024 08:27	6/7/2024 13:16	70299763042	Lead	<1.0	5	ug/L
E-44 BACKHALL C-BF	5/24/2024 08:28	6/7/2024 13:24	70299763043	Lead	<1.0	5	ug/L
E-45 BACKHALL C-F	5/24/2024 08:29	6/7/2024 13:25	70299763044	Lead	<1.0	5	ug/L
E-46 BACKHALL-L-F	5/24/2024 08:30	6/7/2024 13:27	70299763045	Lead	<1.0	5	ug/L
E-47 RM34	5/24/2024 08:32	6/7/2024 13:28	70299763046	Lead	<1.0	5	ug/L
E-48 FACULTY	5/24/2024 08:33	6/7/2024 13:30	70299763047	Lead	<1.0	5	ug/L
E-49 BOYS LR-BF	5/24/2024 08:35	6/7/2024 13:31	70299763048	Lead	<1.0	5	ug/L
E-50 BOYS LR-F	5/24/2024 08:35	6/7/2024 13:33	70299763049	Lead	<1.0	5	ug/L
E-51 GIRLS LR-BF	5/24/2024 08:37	6/7/2024 13:35	70299763050	Lead	<1.0	5	ug/L

E-52 GIRLS LR-F	5/24/2024 08:37	6/7/2024 13:36	70299763051	Lead	<1.0	5	ug/L
E-53 KITCHEN ICE	5/24/2024 08:45	6/7/2024 13:41	70299763052	Lead	<1.0	5	ug/L
E-54 KITCHEN VEG	5/24/2024 08:46	6/7/2024 13:42	70299763053	Lead	6.6	5	ug/L
E-55 KITCHEN PREP	5/24/2024 08:47	6/7/2024 13:44	70299763054	Lead	2.2	5	ug/L
E-56 KITCHEN BWS	5/24/2024 08:48	6/7/2024 13:45	70299763055	Lead	4.7	5	ug/L
E-57 KITCHEN PFR	5/24/2024 08:49	6/7/2024 13:47	70299763056	Lead	1.2	5	ug/L
E-58 KITCHEN PFC	5/24/2024 08:49	6/7/2024 13:48	70299763057	Lead	1.3	5	ug/L
E-59 KITCHEN PFL	5/24/2024 08:50	6/7/2024 13:50	70299763058	Lead	1.0	5	ug/L
E-60 KITCHEN 3BR	5/24/2024 08:51	6/7/2024 13:51	70299763059	Lead	1.2	5	ug/L
E-61 KITCHEN 3BL	5/24/2024 08:51	6/7/2024 13:53	70299763060	Lead	1.4	5	ug/L
E-62 -MP-BF	5/24/2024 08:40	6/7/2024 14:00	70299763061	Lead	<1.0	5	ug/L
E-63 -MP-FL	5/24/2024 08:42	6/7/2024 14:05	70299763062	Lead	<1.0	5	ug/L
E-64 -MP-FR	5/24/2024 08:43	6/7/2024 14:09	70299763063	Lead	<1.0	5	ug/L
E-65 MUSIC F	5/24/2024 08:39	6/7/2024 14:11	70299763064	Lead	<1.0	5	ug/L
E-66 MUSIC BF	5/24/2024 08:39	6/7/2024 14:13	70299763065	Lead	<1.0	5	ug/L
E-67 2/3-F	5/24/2024 08:02	6/7/2024 14:17	70299763066	Lead	<1.0	5	ug/L
E-68 2/3-BF	5/24/2024 08:03	6/7/2024 14:19	70299763067	Lead	<1.0	5	ug/L
T-01 TRACK SPIGOT	5/24/2024 11:05	6/7/2024 14:20	70299763068	Lead	<1.0	5	ug/L
MS-1 NURSE	5/24/2024 08:54	6/7/2024 14:22	70299763069	Lead	3.0	5	ug/L
MS-2 LOBBY-L BF	5/24/2024 08:55	6/7/2024 14:23	70299763070	Lead	<1.0	5	ug/L
MS-3 LOBBY-L F	5/24/2024 08:51	6/7/2024 14:25	70299763071	Lead	<1.0	5	ug/L
MS-5 2ND FLORR BBF	5/24/2024 09:05	6/7/2024 14:26	70299763072	Lead	<1.0	5	ug/L
MS-6 2ND FLOOR BF	5/24/2024 09:10	6/7/2024 14:28	70299763073	Lead	<1.0	5	ug/L
MS-7 LIBRARY -BF	5/24/2024 09:13	6/7/2024 14:29	70299763074	Lead	<1.0	5	ug/L
MS-8 LIBRARY -F	5/24/2024 09:14	6/7/2024 14:31	70299763075	Lead	<1.0	5	ug/L
MS-9 LIBRARY -RF	5/24/2024 09:15	6/7/2024 14:36	70299763076	Lead	<1.0	5	ug/L
MS-10 RM136 BF	5/24/2024 09:05	6/7/2024 14:37	70299763077	Lead	<1.0	5	ug/L
MS-11 RM136 LF	5/24/2024 09:05	6/7/2024 14:39	70299763078	Lead	<1.0	5	ug/L
MS-12 RM136 RF	5/24/2024 09:06	6/7/2024 14:40	70299763079	Lead	<1.0	5	ug/L
MS-13 105 SINK	5/24/2024 09:00	6/7/2024 14:42	70299763080	Lead	<1.0	5	ug/L
MS-14 205 F	5/24/2024 09:12	6/7/2024 14:46	70299763081	Lead	<1.0	5	ug/L
MS-15 205 BF	5/24/2024 09:11	6/7/2024 14:54	70299763082	Lead	<1.0	5	ug/L
MS-16 CONN-F	5/24/2024 09:03	6/7/2024 14:58	70299763083	Lead	<1.0	5	ug/L
MS-17 CONN-BF	5/24/2024 09:03	6/7/2024 15:00	70299763084	Lead	<1.0	5	ug/L
HS-1 CONS SINK	5/24/2024 09:31	6/7/2024 15:01	70299763085	Lead	<1.0	5	ug/L
HS-2 CONS 3BS	5/24/2024 09:32	6/7/2024 15:03	70299763086	Lead	1.2	5	ug/L
HS-3 CONS ICE	5/24/2024 09:33	6/7/2024 15:04	70299763087	Lead	<1.0	5	ug/L
HS-4 CONS WINDOW	5/24/2024 09:34	6/7/2024 15:06	70299763088	Lead	1.2	5	ug/L
HS-05 DO KITCHEN	5/24/2024 09:38	6/7/2024 15:07	70299763089	Lead	1.4	5	ug/L
HS-06 AT ICE	5/24/2024 09:42	6/7/2024 15:12	70299763090	Lead	<1.0	5	ug/L
HS-07 AT SINK	5/24/2024 09:42	6/7/2024 15:14	70299763091	Lead	4.8	5	ug/L
HS-08 ATH BF	5/24/2024 09:44	6/7/2024 15:15	70299763092	Lead	<1.0	5	ug/L
HS-09 ATH F	5/24/2024 09:45	6/7/2024 15:17	70299763093	Lead	<1.0	5	ug/L
HS-10 ATH FR	5/24/2024 09:45	6/7/2024 15:18	70299763094	Lead	<1.0	5	ug/L
HS-11 KITCH-OVEN	5/24/2024 09:48	6/7/2024 15:20	70299763095	Lead	2.9	5	ug/L
HS-12 KITCH-PFL	5/24/2024 09:48	6/7/2024 15:21	70299763096	Lead	1.2	5	ug/L
HS-13 KITCH-PF R	5/24/2024 09:49	6/7/2024 15:23	70299763097	Lead	2.9	5	ug/L
HS-14 KITCH 3BR	5/24/2024 09:50	6/7/2024 15:24	70299763098	Lead	12.3	5	ug/L
HS-15 KITCH 3BL	5/24/2024 09:51	6/7/2024 15:26	70299763099	Lead	9.1	5	ug/L
HS-16 KITCHEN ICE	5/24/2024 09:53	6/7/2024 15:30	70299763100	Lead	<1.0	5	ug/L
HS-17 GYM/CAFE BF	5/24/2024 09:54	6/7/2024 15:35	70299763101	Lead	<1.0	5	ug/L
HS-18 GYM/CAFE F	5/24/2024 09:54	6/7/2024 15:40	70299763102	Lead	<1.0	5	ug/L

HS-19 LOBBY BF	5/24/2024 09:56	6/7/2024 15:44	70299763103	Lead	<1.0	5	ug/L
HS-20 LOBBY F	5/24/2024 09:57	6/7/2024 15:49	70299763104	Lead	<1.0	5	ug/L
HS-21- NURSE BF	5/24/2024 09:57	6/7/2024 15:50	70299763105	Lead	<1.0	5	ug/L
HS-22 NURSE F	5/24/2024 09:59	6/7/2024 15:52	70299763106	Lead	<1.0	5	ug/L
HS-23 204-BF	5/24/2024 10:00	6/7/2024 15:53	70299763107	Lead	<1.0	5	ug/L
HS-24 204-F	5/24/2024 10:02	6/7/2024 15:55	70299763108	Lead	<1.0	5	ug/L
HS-25 AUD BF	5/24/2024 10:02	6/7/2024 15:56	70299763109	Lead	<1.0	5	ug/L
HS-26 AUD F	5/24/2024 10:06	6/7/2024 15:58	70299763110	Lead	<1.0	5	ug/L
HS-27 NURSE TREAT	5/24/2024 10:04	6/7/2024 15:59	70299763111	Lead	2.3	5	ug/L
HS-28 NURSE RECEP	5/24/2024 10:04	6/7/2024 16:01	70299763112	Lead	2.2	5	ug/L
HS-29 214 SINK	5/24/2024 10:11	6/7/2024 16:03	70299763113	Lead	2.9	5	ug/L
HS-30 LIBRARY-F	5/24/2024 10:12	6/7/2024 16:07	70299763114	Lead	1.3	5	ug/L
HS-31 RSO SINK	5/24/2024 10:13	6/7/2024 16:09	70299763115	Lead	<1.0	5	ug/L
HS-32 ISO SINK	5/24/2024 10:17	6/7/2024 16:10	70299763116	Lead	2.0	5	ug/L
HS-33 117 A-SINK	5/24/2024 10:18	6/7/2024 16:12	70299763117	Lead	1.3	5	ug/L
HS-34 105 R	5/24/2024 10:20	6/7/2024 16:13	70299763118	Lead	5.2	5	ug/L
HS-35 105 RR	5/24/2024 10:21	6/7/2024 16:15	70299763119	Lead	84.3	5	ug/L
HS-36 105 L	5/24/2024 10:22	6/7/2024 16:16	70299763120	Lead	3.4	5	ug/L
HS-37 105 LR	5/24/2024 10:22	6/7/2024 16:21	70299763121	Lead	6.2	5	ug/L
HS-38 103 BF	5/24/2024 10:24	6/7/2024 16:28	70299763122	Lead	<1.0	5	ug/L
HS-39 103 -F	5/24/2024 10:25	6/7/2024 16:33	70299763123	Lead	<1.0	5	ug/L
HS-40 BAND BF	5/24/2024 10:26	6/7/2024 16:34	70299763124	Lead	<1.0	5	ug/L
HS-41 BAND -F	5/24/2024 10:28	6/7/2024 16:36	70299763125	Lead	<1.0	5	ug/L
HS-42 LOBBY FR	5/24/2024 10:32	6/7/2024 16:37	70299763126	Lead	<1.0	5	ug/L
HS-43 CONC BF	5/24/2024 09:36	6/7/2024 16:39	70299763127	Lead	<1.0	5	ug/L
HS-44 CONC F	5/24/2024 09:36	6/7/2024 16:44	70299763128	Lead	<1.0	5	ug/L
HS-45 CON FR	5/24/2024 09:37	6/7/2024 16:45	70299763129	Lead	<1.0	5	ug/L
HS-46 340- F	5/24/2024 10:35	6/7/2024 16:47	70299763130	Lead	<1.0	5	ug/L
HS-47 340- BF	5/24/2024 10:35	6/7/2024 16:48	70299763131	Lead	<1.0	5	ug/L
HS-48 340 FR	5/24/2024 10:37	6/7/2024 16:50	70299763132	Lead	<1.0	5	ug/L
HS-49 OUTSIDE TECH	5/24/2024 10:40	6/7/2024 16:51	70299763133	Lead	2.3	5	ug/L

NYSDOH Action Level for Lead In Schools of 5 ppb